

Certificate of Accreditation

Amendment 2

NUCLAD EXTERIOR INSULATION AND FINISHING SYSTEM

Nutex Coatings
287 Wellington Road
MULGRAVE VIC 3170

has applied to the Building Regulations Advisory Committee for the accreditation of **NuCLAD Exterior Insulation and Finishing System**, as suitable for use as a wall cladding system in Class 1 and associated Class 10 buildings.

The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the *Building Act 1993* has examined the application and determined that **NuCLAD Exterior Insulation and Finishing System** complies with Performance Requirements:

P2.1.1 and P2.2.2

of **Volume Two of the National Construction Code - Building Code of Australia** as adopted by the building regulations as in force from time to time, to the extent that those Clauses refer to the structural stability, resistance to wind action and rainwater action, and weatherproofing of the product, subject to the following conditions:

1. This accreditation applies in the State of Victoria and is limited to –
 - a. Class 1 and 10 buildings;
 - b. Installation height up to a maximum of 6m to the underside of eaves and 8.5m to the ridge height;
 - c. Installation width of the building including verandas, excluding eaves, up to a maximum of 16m;
 - d. Installation length of the building up to a maximum of five times the building width;
 - e. Buildings with a maximum roof pitch of 35 degrees; and
 - f. Buildings built in Region A, non-cyclonic wind classes N1 – N2 as per Australian Standard AS 4055 – 2006.
2. The product must be installed, including rendering, in accordance with the NuCLAD EIFS Technical Manual (document number TM001, Version No. V03 revised 7 August 2019 as provided by NuCLAD).
3. The product must only be used with the Watergate vapour permeable sarking membrane behind the panels and Aluband/Aluminium window sealing system.

This accreditation does not apply to any other provisions of the National Construction Code Series.

Building

Regulations Advisory Committee

Signature:



Commissioner Yvonne von Hartel AM
Chair, Building Regulations Advisory Committee

Certificate Number: V12/04-A2
Date of issue: 30 October 2012

Amendment 1 (A1)
Nature of amendment: To update references to performance requirements.
Date of amendment: 20 September 2017

Amendment 2 (A2)
Nature of amendment: Reference to amended Manual TM001 V03 dated 7 August 2019.
Date of amendment: 25 September 2019